

In response quote reference: M 1798711
In response enquire to: Dave Richards



19 October 2021

Tanker Filling from designated Fire hydrants Application

Applicant Details

First Name: _____ Last Name: _____

Company: _____

Postal Address: _____

Phone: _____ Mobile: _____

E-mail: _____ Fax: _____

Please indicate Backflow Prevention device you will be using:

- 25mm Air Gap
- Reduced pressure Zone device (RPZ). Please send documentation of this device with your application.

Please indicate if you intend to take water for potable use:

- Yes – I intend to take water for potable water supply. MOH REG # _____
- No – Water is not for potable water supply.

For Ministry of Health registration assistance, Inquiries can be made to;
Waikato District Health Board

Application Declaration

I, the undersigned, hereby declare the information given on this application is true and correct and that I am aware of the conditions of use overleaf and will abide by the conditions of use, council's bylaws and regulations.

Name (please print): _____

Signature: _____ Date: _____

Permit Conditions.

1. Any person or contractor wishing to take water from Hauraki District Council mains must have a current Permit.
2. Permit holders are required to provide either meter readings or tanker quantities taken on a monthly basis. Consumption will be billed accordingly. Water will be charged on a per M³ rate as per the Hauraki District Council Annual Plan fees and charges schedule current at the time of drawing water.
3. An annual examination and meter check may be made of all units or more frequently at the sole discretion of Hauraki District Council.
4. All activities relating to the use of bulk water filling points shall comply with Hauraki district Council bylaws, including compliance with the Drinking water standards for New Zealand water carriers requirements.
5. The hydrant must be operated in a proper manner, that is, just cracked open until the hose is full and then slowly opened and closed. Rapid spinning of the valve key is not permitted. The hydrant must not be over tightened when closing – this damages the seals.
6. The contractor is responsible for public safety and must follow the traffic management plan for each hydrant site.
7. Council will not be liable for any accident or damage to persons or property, including the road or footpath/berm surface and the hydrant or water reticulation. The contractor must ensure that they maintain adequate public liability Insurance.
8. Council gives no guarantee of water quality, quantity, or pressure in the main.
9. Only hydrants listed as bulk filling points are to be used. Drawing water from hydrants elsewhere in the district is strictly prohibited unless specific written approval is first obtained.
10. If the water is intended for human consumption, it is the contractors responsibility to ensure that the water delivered is of potable quality.
11. Council reserves the right to direct the contractor to take from specific hydrants, to take only at specific times of day and to cease to take from any or all hydrants at any time and for any duration.
12. The permit holder shall not take water from Hauraki District Council hydrants in areas where water restrictions are in force unless prior approval is given from utilities department.
13. Failure to comply with these conditions will lead to the permit being revoked.